


STANDARD CONSTRUCTION

- HANGER BRACKETS CONSTRUCTED OUT OF 12 GAUGE GALVANIZED STEEL.
- 4 BRACKETS PER UNIT.
- LAYOUT INDICATES SUGGESTED HANGER BRACKET LOCATIONS
- BRACKETS ARE SHIPPED LOOSE FOR FIELD INSTALLATION FOR USE WITH FASTENERS AND THREADED HANGER RODS (BY OTHERS).




WITH CONTROLS ENCLOSURE


ALL METRIC DIMENSIONS [] ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER

PROJECT: APPROVED BY: DDV **ENGINEER:** H **DUAL DUCT TERMINAL** DRAWING NO: **CUSTOMER:** VARIABLE VOLUME 276717 **NON-MIXING** DATE DRAWN: **SUBMITTAL DATE:** SPEC. SYMBOL: HANGER BRACKET 2024-02-20

Submittal Sheet



UNIT	INLET SIZES	WIDTH	HEIGHT	CENTER-TO-CENTER
SIZE	D	W	Н	Α
4	3 ⁷ / ₈ (98)			
5	4 ⁷ / ₈ (124)		8 (203)	
6	5 ⁷ / ₈ (149)	24 ¹ / ₈ (613)		12 ¹ / ₈ (308)
7	6 ⁷ / ₈ (175)		10 (254)	
8	$7^{7}/_{8}(200)$		10 (234)	
9	8 ⁷ / ₈ (225)	28 ¹ / ₈ (714)	12 ¹ / ₂ (318)	14 ¹ / ₈ (359)
10	9 ⁷ / ₈ (251)			
12	11 ⁷ / ₈ (302)	32 ¹ / ₈ (816)	15 (381)	16 ¹ / ₈ (410)
14	13 ⁷ / ₈ (352)	40 ¹ / ₈ (1019)	17 ¹ / ₂ (445)	20 ¹ / ₈ (511)
16	15 ⁷ / ₈ (403)	48 ¹ / ₈ (1222)	18 (457)	24 ¹ / ₈ (613)



STANDARD CONSTRUCTION:

- 1" (25mm) THICK INTERNAL FIBERGLASS INSULATION WHICH MEETS REQUIREMENTS OF NFPA 90A AND UL181.
- 22 GAUGE GALVANIZED STEEL HOUSING. MECHANICALLY SEALED, LEAK RESISTANT CONSTRUCTION.
- RECTANGULAR DISCHARGE OPENING WITH SLIP AND DRIVE CLEAT DUCT CONNECTION.
- MULTI-POINT, CENTER AVERAGING AIRFLOW SENSOR.
- 1/2" (13mm) GALVANIZED DAMPER SHAFT WITH POSITION INDICATOR.

CONTROLS OPTIONS:

□ FIELD MOUNTED CONTROLS, SUPPLIED BY OTHERS (FLD)

□ FACTORY MOUNTED DIGITAL CONTROLS, SUPPLIED BY OTHERS (FAC)

□ FACTORY MOUNTED DIGITAL CONTROLS, SUPPLIED BY PRICE (EHPD)

□ FACTORY MOUNTED PNEUMATIC CONTROLS, SUPPLIED BY PRICE (EHPP)

UNIT OPTIONS:

□ NEMA1 CONTROLS ENCLOSURE (PS)

□ DISCONNECT SWITCH (DSW)

□ HANGER BRACKETS (HB)

□BRASS AIRFLOW SENSOR GAUGE TAPS (GT)

LINER OPTIONS:

□ FIBER FREE FOAM 1" (25mm) (FF1)

□ SOLID METAL WITH FG1 (SM1)

□ CLEANROOM ANGLES WITH FB1 (CRAF1)

□ PERFORATED METAL WITH FB1 (AFPM1)

□ CLEANROOM ANGLES (CA) WITH FG1 OR FF1

PROJECT:

APPROVED BY:

DDV

DUAL DUCT TERM

ALL METRIC DIMENSIONS [] ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER

CUSTOMER:

DRAWING NO:
276718

SUBMITTAL DATE:

SPEC. SYMBOL:

DATE DRAWN:
2024-02-20

DDV
DUAL DUCT TERMINAL
VARIABLE VOLUME
NON-MIXING
CONTROL BOTTOM