



MANUAL – INSTALLATION



# Price Rooftop Unit Controller

## PRTU Series



# PRICE ROOFTOP UNIT CONTROLLER

## TABLE OF CONTENTS

### Product Overview

Safety Precautions .....	1
Introduction .....	1
Features .....	1
PRTU Default Sequence of Operations.....	2
Included in Package .....	4
Overview of the PRTU .....	5

### Installations & Mounting Instructions

PRTU Controller .....	6
PRTU Thermostat .....	7
PRTU Wiring .....	8
PRTU Thermostat Wiring.....	9
Zone Polling via BACnet MS/TP Network .....	10
Networking Setup .....	11
Wizard Menu.....	14

### Display Navigation

LCD Thermostat – Initial Start-Up .....	16
Service Menu and Time/Mode Buttons .....	16
Service Menu .....	17
Strategy Menu.....	18
Strategy Menu – Seasonal Strategy.....	19
Setpoint Menu.....	20
Input Menu.....	21
Output Menu – Binary .....	22
Output Menu – Analog .....	23
BACnet Menu (Addressing) .....	26
Stat Setup Menu .....	27
Diagnostic Menu .....	28
Time/Date Set Menu .....	29
Schedule Menu .....	30
Operation Menu .....	31
Wizard Menu.....	32

### Maintenance

Troubleshooting Guide.....	33
Hardware Specification.....	35
Commissioning Checklist .....	36

## SUPPORT ▼

Having difficulty installing this product?  
Price is here to help.

### Application Support

204.654.5613 option 4  
controls@priceindustries.com  
priceindustries.com/controls

# PRICE ROOFTOP UNIT CONTROLLER

## PRODUCT OVERVIEW

### Safety Precautions

Short Circuit or incorrect wiring may permanently damage the controls or other equipment. Ensure proper wiring practices. The PRTU is to be used only as an operating controller. If a control failure could lead to personal and/or property damage, the installer must add safety/interlock devices to protect against these events.

### Introduction

The Price Rooftop Unit Controller (PRTU) is intended to provide intelligent control of packaged single and multi-stage rooftop equipment typically in the 2-30 ton range. A variety of configurable binary and analog outputs allow control of virtually all rooftop units. All models feature 10 protected binary outputs and 4 protected analog outputs. Indicator LEDs show status of each output in green, red or yellow.

The PRTU comes with a backlit LCD Thermostat with password protected menus to fully configure and setup the unit in the field. Accurate temperature control is accomplished with a proportional integral (PI) algorithm.

The PRTU can function in **standalone mode (not networked to any zone controllers)** or can be networked to poll Price Controllers (Price Intelligent Controller - PIC, Prodigy Smart Diffuser) via BACnet MS/TP.

### Features

#### PRTU Controller

- On board Real Time Clock and Calendar for scheduling
- Super Capacitor backup keeps time clock running during power failures
- Discharge Air Temperature (D.A.T.) monitoring – prevents excessive temperature swings that can trip safeties and waste energy
- Return Air Temperature (R.A.T) monitoring – monitors return air to RTU and prevents freeze up of coil or overheating that can trip safeties and waste energy
- 10 binary outputs rated at 0.5 amps each, protected with thermal fuse (RED LED on trip), automatic recovery when fault is corrected
- Switch for selecting binary output type (24VAC – HOT, COMMON or external)
- 4 analog outputs (0-10VDC), fully configurable for FAN, heating, cooling and spare
- Multi-level surge protection with user replaceable MINI type fuse (10 Amp)
- Pluggable terminal blocks
- BACnet MS/TP Client/Server stack for polling zones for data
- LED's for BACnet wiring fault, BACnet network fault, and MS/TP termination

#### PRTU Thermostat

- Backlit 14 x 2 LCD Thermostat with true character display
- Motion Sensor on Thermostat allows automatic occupancy mode
- Password protected menu
- Easy to use MENU system for fast and simple setup of system
- Local precision Thermistor
- Included RJ-45 plenum rated cable for fast, error free hookup
- Setup Wizard – walk through setup of PRTU when first powered up

# PRICE ROOFTOP UNIT CONTROLLER

## PRODUCT OVERVIEW

### PRTU Default Sequence of Operations

The PRTU can function in standalone mode (not networked to any zone controllers) or can be networked to poll Price Controllers (Price Intelligent Controller – PIC, Prodigy Smart Diffuser) via BACnet MS/TP. If set to networked mode and the PRTU cannot poll the zones properly due to, bad address, bad wiring, etc. the unit will show BACnet Health of 0% and will default to standalone mode. If more than 50% of the network is online communicating with the PRTU, the PRTU will poll the devices which are communicating. (If greater than 50% of the network is offline the PRTU will default to standalone) In standalone mode the PRTU uses its local Thermostat and Setpoints to control the RTU. This is why we recommend locating/mounting PRTU Stat in a common area that the RTU services (eg. A hallway or open area, ideally not a mechanical room).

### Standalone Mode

In this mode the PRTU will control the packaged RTU based on the local temperature conditions as measured at the PRTU Thermostat.

On an increase in space temperature into the cooling proportional band the PRTU will progressively engage stages of cooling (up to 4) in the packaged rooftop unit. On an increase of space temperature greater than the cooling proportional band, all active cooling stages will be energized. As the space temperature approaches the cooling Setpoint, the PRTU will de-energize active cooling stages.

On a decrease in space temperature into the heating proportional band the PRTU will progressively engage stages of heating (up to 4) in the packaged rooftop unit. On a decrease of space temperature greater than the heating proportional band, all active heating stages will be energized. As the space temperature approaches the heating Setpoint, the PRTU will de-energize active heating stages.

Separate heating and cooling Setpoints, along with adjustable changeover timers prevent system cycling between heating and cooling modes. Heating and cooling Setpoints are separated by a default value of 4°F (2°C).

Using the included two 10k Thermistor probes (Type J), the PRTU will monitor the air temperature as it is discharged (D.A.T. – measured on AI1) and returned (R.A.T. – measured on AI2) to the rooftop unit.

If either of the air temperatures exceed the adjustable limits, active heating and cooling stages are de-energized to prevent low or high temperature lockouts in the packaged rooftop unit.

Adjustable minimum on/off times prevent short cycling of outputs.

### Networked Mode

In this mode the PRTU will poll up to 30 zone controllers (Price Intelligent Controller (PIC) or Prodigy Smart Diffusers). The number of zones polled must be set in the field. The PRTU will poll the requested zones every 3 minutes. Data polled is room temperature and room Setpoint.

### Average Polling – (Recommend for most applications)

In average polling mode the majority demand wins and the RTU will be controlled using that information.

Example: Cooling – 50%, Heat – 40%, Neutral - 10% = Cooling Wins.

Each zone can be weighted. The default is 1. To add more weight to a zone (example: a large meeting room, or VIP room) increase the weight. Increasing the weight to 3 would give that zone 3 votes instead of 1.

To disable a zone set polling to 0. This is ideal for a zone which is poorly supplied and is influencing the system in a non-ideal way.

### Networked Mode – Non-majority polling

Non majority favours one of the 3 modes.

Useful for:

- Heat/cool changeover systems WITH reheat at zones (favour cooling)
- Summer: Favour cooling
- Winter: Favour heating

PRTU can be set to switch strategies automatically on season change via the real time clock and calendar. This must be setup in the field.

# PRICE ROOFTOP CONTROLLER

## PRODUCT OVERVIEW

### Night Setback Mode

The PRTU uses a default Occupied schedule that is set to run from 6am to 8pm (adjustable). When the schedule falls outside of this range, the PRTU will be set to Unoccupied Mode and will operate to its Night Setback (Unoccupied) setpoints.

### Night Setback Mode – Networked Polling Mode

#### Unoccupied Heating Mode:

The PRTU uses a Night Heat Setpoint of 62 Deg F (adjustable). During unoccupied mode, if at least one of the connected zone controllers' space temperature falls below 62 Deg F, the mode will be set to heating on the PRTU. Based on how far away the space temperature is from this setpoint will determine how many stages of heating will be enabled. The further away from setpoint, two to four stages of heating will be enabled. Once the space temperature within the calling zone exceeds 62 Deg F, heating will be disabled at this time.

Additionally, if the zone controller has a form of reheat like a hot water or electric reheat coil, and the space temperature drops below 62 Deg F, the controller will enable its local reheat at this time.

**NOTE:** Electric reheat will only engage if there is sufficient airflow from the RTU. If airflow is not present, the electric reheat will not engage.

#### Unoccupied Cooling Mode:

The PRTU uses a default Night Cooling Setpoint of 63 Deg F (adjustable). During unoccupied mode, if at least one of the connected zone controllers' space temperature rises above 83 Deg F, the mode will be set to cooling on the PRTU. Based on how far away the space temperature is from this setpoint will determine how many stages of cooling will be enabled. The further away from setpoint, two to four stages of cooling will be enabled.

#### Unoccupied Deadband Mode:

When all the connected zone controllers' space temperatures are within their set Day Differential (1 Deg F default), the system will be in Deadband mode and said to be satisfied.

### Night Setback Mode – Standalone Mode

#### Unoccupied Heating Mode:

When the PRTU is in Standalone mode, it uses its own local temperature and setpoint to control the RTU. If the space temperature falls below 62 Deg F, heating mode will be engaged.

#### Unoccupied Cooling Mode:

If the space temperature rises above 83 Deg F, cooling mode will be engaged.

#### Unoccupied Deadband Mode:

When the local temperature at the PRTU System Controller thermostat is within the Day Differential (1 Deg F default), the system will be in Deadband mode and said to be satisfied.

# PRICE ROOFTOP UNIT CONTROLLER

## PRODUCT OVERVIEW

### Included in Package

Each PRTU ships with the following items:

1. PRTU Controller (with DIN rail for mounting) (250000-900)
2. PRTU Thermostat (with backlit LCD screen) (250000-910)
3. Plenum rated 35-foot (RJ-45) Thermostat cable (228709-001)
4. Two 10k temperature probes (Type J) (250000-052)
5. Price Electronics Flat head screwdriver (0.1" tip) (020508-003)
6. PRTU - Quick Start Guide (1 page, double-sided)
7. This Manual

Please ensure you have all components before proceeding. Inspect components for shipping damage. Do not install components that appear damaged, contact your local PRICE Sales Rep for quick ship replacements.

As always for the latest information and video please visit [priceindustries.com](http://priceindustries.com).

### INCLUDED ITEMS ▼



1. PRTU CONTROLLER



2. PRTU THERMOSTAT




3. PLENUM RATED 35-FOOT (RJ-45) THERMOSTAT CABLE



4. TWO 10K TEMPERATURE PROBES



5. PRICE ELECTRONICS FLAT HEAD SCREWDRIVER



6. PRTU - QUICK START GUIDE




7. THIS MANUAL

# PRICE ROOFTOP UNIT CONTROLLER

## PRODUCT OVERVIEW

### OVERVIEW OF THE PRTU ▼



ALL METRIC DIMENSIONS ( ) ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

# PRICE ROOFTOP UNIT CONTROLLER

## INSTALLATION & MOUNTING INSTRUCTIONS

### PRTU Controller


To mount the PRTU controller use the included 11" piece of DIN rail. The PRTU must NOT be installed outdoors or inside the RTU. Mount the PRTU on the wall in a mechanical or IT room or install in the plenum space in an approved enclosure, ideally near the main ductwork supply/return of the RTU just above the ceiling tiles.

1. Using 3 screws (by others) mount the DIN rail horizontally to a secure, accessible surface
2. Hang the PRTU controller onto the DIN rail using the TOP white clips
3. Using the Price Electronics screwdriver, gently pull down on the BLACK clip, while pushing gently on the PRTU towards the DIN rail
4. The PRTU should click securely into place
5. To remove, repeat above steps in reverse


### DIN RAIL ▼



### BACK VIEW OF PRTU ▼



### FRONT VIEW OF PRTU MOUNTED ON DIN RAIL ▼



# PRICE ROOFTOP UNIT CONTROLLER

## INSTALLATION & MOUNTING INSTRUCTIONS

### PRTU Thermostat

The PRTU Thermostat must be mounted to a wall and wired to the PRTU Controller via the supplied plenum rated 35 ft CAT-5 cable. The cable plugs into the Thermostat and the PRTU T-STAT jack with a RJ-45 connection.

**NOTE:** The cable run can be extended to 70 ft using a Price cable coupler (NETCC) and additional 35 ft cable (NETC35).

### Location

To mount the PRTU Thermostat remove the back plate gently lifting from the bottom. Mount the back plate/Thermostat in common area such as a hallway. This allows the motion sensor to detect people during unoccupied periods. Also if the system needs to operate in standalone mode (using the Thermostat temperature sensor) this allows adequate control of the PRTU.

- Do not mount the Thermostat in direct sunlight (ie: across from a window)
- Do not install on an exterior wall
- Do not mount near equipment that generates heat (monitors, fridge, photocopiers, etc.)
- Ensure nothing will restrict vertical air circulation to the Thermostat (ie: do not cover, enclose, etc.)
- Ensure wall is NOT pressurized! Hot/Cold air from a pressurized wall will directly blow onto the Thermostat's temperature sensor causing 'bad' readings.

### Installation Steps


1. The back plate on each Thermostat is removable and can be mounted to a standard electrical box or directly to drywall using anchors supplied by others.
2. Run the CAT-5 cable through the center hole in the plate. Connect the cable to the Thermostat, and then secure the Thermostat onto the wall plate inserting the top portion of the Thermostat first, and then snapping the bottom half in.
3. All Thermostats will come equipped with 0.050" Allen Key for the set screw at the bottom. This helps secure the Thermostat and prevents users from removing it.

### TECH TIP ▼

Careful Thermostat installation will reduce field issues! Do not twist or kink the blue CAT-5 Thermostat cable. Damaged cables are difficult to troubleshoot!

**Thermostat cable product code: NETC35**

### SURFACE MOUNT DETAIL ▼



### PRTU THERMOSTAT ▼



# PRICE ROOFTOP UNIT CONTROLLER


## INSTALLATION & MOUNTING INSTRUCTIONS

### PRTU Wiring

Wiring of the PRTU to the packaged rooftop unit is simple, but still requires attention to detail. In virtually all installations the PRTU will be powered from the RTU 24VAC transformer. **24VAC HOT and COMMON polarities are critical and must be observed throughout the wiring process!**

As with most 24VAC powered devices, reversing polarity still allows the device to power up, but once connected to another device undesirable results will occur. These are typically difficult to troubleshoot and consume valuable time.

### TYPICAL HOOKUP TO A 2 STAGE HEAT/COOL UNIT WITH A BINARY FAN ▼



### TECH TIP ▼

Ensure 24VAC polarity is correct and consistent among all devices! Ensure 24VAC COMMON is earth grounded.


# PRICE ROOFTOP UNIT CONTROLLER

## INSTALLATION & MOUNTING INSTRUCTIONS

### PRTU Thermostat Wiring

Plug Thermostat cable into RJ-45 Jack of the Thermostat and in RJ-45 jack labeled T-STAT on PRTU. Thermostat gets power from PRTU, which is getting 24VAC from Rooftop unit. On power up, Thermostat displays its firmware version V3.XX.X and PRTU firmware version V1.XX.X.

CAPTION ▼



# PRICE ROOFTOP UNIT CONTROLLER

## INSTALLATION & MOUNTING INSTRUCTIONS

### Zone Polling via BACnet MS/TP Network

The PRTU can poll zones for load data (room temperature and room Setpoint) over a BACnet MS/TP connection (a.k.a. the NETWORK). Price Controllers that support BACnet and zone control are currently the Price Intelligent Controller (PIC) and Prodigy Smart Diffuser (PPD). To simplify the wiring of MS/TP Price uses an RJ-45 connection. Pins 1 and 2 are used for the MS/TP data (+ and -), while Pins 7 and 8 are used for a BACnet common connection. Pins 3, 4, 5, 6 are no connects. Please note this is not an Ethernet connection! Price uses RJ-45 jacks and cable due to their excellent specifications and availability.

The PRTU has both a RJ-45 connection and a 3 position terminal plug that can access the MS/TP port. Typically you will use the RJ-45 connection to connect to the ZONE CONTROLLERS.

Before networking to the controllers please use the checklist below:

- All zone controllers are powered up and functioning
- All zone controllers have consistent 24VAC HOT and 24VAC COMMON power correctly hooked up
- Each zone controller has a UNIQUE MAC Address starting at 1 and going up to a maximum of 30
- Each zone controller has a UNIQUE DEVICE INSTANCE address starting at 101 (going to 130)
- Each zone controller is running at a MS/TP baud rate of 76,800 (Price default for all controllers, recommend you use this and do not change on any controllers)
- All controllers must be wired in DAISY CHAIN format. Controller to controller, no 'T' or split connections
- NOTE:** Bad wiring, Addresses, Baud Rates, etc. will cause network to crash and/or be unreliable. Triple check all wiring and settings! PRTU will run in stand-alone mode unless network is good. Once errors are fixed, PRTU will automatically switch back to networked mode

### BACnet Addressing Tips:

If only installing one PRTU please use the default addresses. Each PRTU has two address types a LOCAL and a SYSTEM address.

On PRTU the LOCAL address (MAC Address) is unique to the MS/TP segment and has a range of 101-126. This ensures it does not collide with the Zone Controllers addresses (which are limited form 1-99).

On PRTU the SYSTEM address (DEVICE INSTANCE) is unique to the building network and has a range of 1-4.19M.

PRTU DEFAULT – MAC - 101

PRTU DEFAULT – INSTANCE - 100

# PRICE ROOFTOP UNIT CONTROLLER

## INSTALLATION & MOUNTING INSTRUCTIONS

### Networking Setup

SETUP WITH NO WEB ACCESS ▼

#### PRTU


- Number of polling zones = 3
- LOCAL/MAC – 101
- SYSTEM/DEVICE INSTANCE – 100

**IMPORTANT:** The LOCAL/MAC of each PIC/PRODIGY would be 1, 2, and 3, while the instances would be 101, 102, 103

#### Termination of MS/TP Network

Each MS/TP Network should be terminated to prevent reflections and ensure a reliable network. Terminate a total of 2 times, once at beginning of the network and once at the last device. In the example below, enable termination at the PRTU (via the BACnet menu) and the last Prodigy/PIC controller using the DIP switch #8 (TRM).

**NOTE:** The PCV does not ship with an LCD T-Stat. To change its instance, you can temporarily borrow an LCD T-Stat from any other controller (eg. Prodigy, PIC or even PRTU) to setup the PCV. Alternatively you can purchase an LCD-SETUP tool or LINKER 2. The MAC Address can be set locally through the dip switches on the attached BACnet module. Always cycle 24VAC power after setting address. Address does not change until you do this.



# PRICE ROOFTOP UNIT CONTROLLER


## INSTALLATION & MOUNTING INSTRUCTIONS

### EXAMPLE: SETUP WITH WEB ACCESS ▼

#### PRTU

- Number of polling zones = 3
- LOCAL/MAC – 101
- SYSTEM/DEVICE INSTANCE – 100

**IMPORTANT:** The LOCAL/MAC of each PIC/PRODIGY would be 1, 2, and 3, while the instances would be 101, 102, 103




# PRICE ROOFTOP UNIT CONTROLLER

## INSTALLATION & MOUNTING INSTRUCTIONS


### EXAMPLE: SETUP WITH MULTIPLE SYSTEMS ▼

#### RTU SYSTEM #1



**NOTE:** Up to a MAXIMUM of 30 devices connected to EACH PRTU

#### RTU SYSTEM #2




**NOTE:** Laptop with Web Browser used for setting up the PRTU-IP-RTR and PRTU-WEB locally. After setup is complete, devices can be accessed using any computer with web browser on building LAN.

# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Wizard Menu


The first time the PRTU is powered on, the attached T-Stat will step through the setup wizard.



# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Wizard Menu Continued...



### TECH TIP ▼

Set the PRTU address using the WIZARD or BACnet menu. Set the PIC or Prodigy addresses using the DIP switches for LOCAL/MAC and the LCD Thermostat for setting the SYSTEM/INSTANCE (ADDRESS MENU). When changing DIP switches you must CYCLE POWER on controller! Since the DIP switches are only read on startup. TIP: Press UP/DOWN buttons on LCD stat at same time, this will display the startup screen and show you the current address. (Works on PRTU, PIC and PRODIGY)

# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### LCD Thermostat – Initial Start-Up

When the LCD Thermostat is first powered from the PRTU controller, it will display the following information: (Also press both UP/DOWN at same time to show this screen anytime.)

<b>PRICE ELECTRONICS</b>	Start-up screen
<b>LCD THERMOSTAT MOTION MODEL</b>	PRTU Thermostat has LCD screen and motion sensor
<b>LCD THERMOSTAT VERSION 3.XX.X</b>	<b>LCD Thermostat</b> – Firmware V3.xx.x or higher
<b>LOADING: 0-100%</b>	<b>Loading Screen</b> – Thermostat pulls in variables from PRTU
<b>PRTU VERSION 1.XX.X</b>	<b>PRTU Controller</b> – Firmware Version 1.xx.x or higher
<b>MAC ADDRESS LOCAL 101</b>	<b>Displays current MAC Address (local MS/TP segment)</b> – Must be unique to MS/TP segment
<b>DEVICE INST. SYSTEM 100</b>	<b>Displays current Device Instance (System address)</b> – Must be unique to building
<b>DEVICE INST. SYSTEM 100</b>	After start-up LCD will cycle between Current Mode, Time/Date and Room Temperature (if in standalone – non-networked mode)

### Service Menu and Time/Mode Buttons

#### ▼ Down Button

Used for menu selection and standalone Setpoint adjustment.

#### ▲ Up Button

Used for menu selection and standalone Setpoint adjustment – press both to display Thermostat Startup screens.

#### ⌚ Time Set Button

Used to set real time clock and calendar. Can be password protected, but this is off by default.

#### ⌘/⌘ Mode Set Button

Used to set mode of the system. Can force Cooling only, Heating only, Ventilation (fan) or Auto-changeover (Default). Can be password protected, but this is off by default.

#### ☐ Menu Button

Used to enter Service Menu. Hold button for 5 seconds to enter the Menu.

**Passcode:** Down, Up, Up, Down

**NOTE:** This is the same passcode for SERVICE and TIME/DATE set buttons.

### CONTROLLER ▼



# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Service Menu

The Service Menu contains all setup and configuration parameters. Each PRTU ships as a standalone controller, in Fahrenheit units and is setup to control a 2-stage heating and 2-stage cooling packaged rooftop unit with a binary fan. All MAIN menus are listed on this page. Use the WIZARD and/or below menus to setup the PRTU for your application.

**Passcode:** Down, Up, Up, Down

**NOTE:** This is the same passcode for Service and Time/Mode set buttons.


<b>SERVICE MENU: STRATEGY</b>	<b>Strategy Menu</b> – Allows setting of standalone and polling modes
<b>SERVICE MENU: SETPOINT</b>	<b>Setpoint Menu</b> – Units, Night heat/cool, and limits
<b>SERVICE MENU: INPUT</b>	<b>Input Menu</b> – T-Stat offset, reading of inputs (AI1-AI12)
<b>SERVICE MENU: OUTPUT</b>	<b>Output</b> – Of binary and analog outputs
<b>SERVICE MENU: BACNET</b>	<b>BACnet Menu</b> – BACnet addresses (MAC and System)
<b>SERVICE MENU: STAT SETUP</b>	<b>Stat Setup Menu</b> – Motion Sensor setup, Time/mode password enable
<b>SERVICE MENU: DIAGNOSTIC</b>	<b>Diagnostic</b> – Displays BACnet health, Zones up
<b>SERVICE MENU: POLLING</b>	<b>Polling Menu</b> – Set # of zones, zone weights, proportional band
<b>SERVICE MENU: TIME/DATE SET</b>	<b>Time/Date Set Menu</b> – Setting of real time clock and calendar
<b>SERVICE MENU: SCHEDULE SET</b>	<b>Schedule Set Menu</b> – Setting of occupancy schedule
<b>SERVICE MENU: OPERATION</b>	<b>Operation Menu</b> – Sets PRTU mode, Fan configuration, # of stages
<b>SERVICE MENU: SETUP WIZARD</b>	<b>Setup Wizard</b> – Steps the user through a simple setup process. Intended to get PRTU up and running quickly. Wizard runs on first power up, but can be re-run at any time
<b>PRESS MENU TO EXIT</b>	<b>Exit Menu</b> – Exits back to main cycle screen

# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Strategy Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Strategy Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Strategy Menu – Seasonal Strategy

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Strategy Menu.

Then select Seasonal Strategy – Yes. This allows automatic changing of the strategy based on Spring, Summer, Fall and Winter. For example you could favor cooling in summer, heating in winter and use standard average polling for spring/fall. The intent is to allow the system to control optimally as the seasons change.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Setpoint Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Setpoint Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Input Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Input Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Output Menu – Binary

Once in Service Menu, Scroll Down and Press ‘Menu/Enter’ to enter the Output Menu.



**B01 – B010** – Default – RTU FAN – Each B01-10 can be re-tasked to either:

- Fan
- Cool 1 (stage 1)
- Cool 2 (stage 2)
- Cool 3 (stage 3)
- Cool 4 (stage 4)
- Heat 1 (stage 1)
- Heat 2 (stage 2)
- Heat 3 (stage 3)
- Heat 4 (stage 4)
- Cool Enable (active on cooling)
- Heat Enable (active on heating)

**Minimum On Time** – This is the minimum time the binary output can be on (regardless of temperature control/etc.)

**Minimum Off Time** – This is the minimum time the binary output will be off (regardless of temperature control/etc.). Intended to prevent short cycling of equipment


\* See page 22 for Output Menu - Analog

# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Output Menu – Analog

Once in Service Menu, Scroll Down and Press ‘Menu/Enter’ to enter the Output Menu.




Continue to next page...

# PRICE INTELLIGENT CONTROLLER

## DISPLAY NAVIGATION

### Output Menu – Analog

Once in Service Menu, Scroll Down and Press ‘Menu/Enter’ to enter the Output Menu.




# PRICE INTELLIGENT CONTROLLER

## DISPLAY NAVIGATION

### Output Menu – Analog

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Output Menu.

Continued from previous page...




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### BACnet Menu (Addressing)

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the BACnet Menu.



### Device Instance - Detail

Tier 0 is always "00" on PRTU

Tier 1 is the MAC Address minus 100 (Range 1-26, Default: 1)

Tier 2 is settable between 0 and 99 (Default: 0)

Tier 3 is settable between 0 and 4 (Default: 0)

Factory default local/MAC Address: 101

Factory system/Instance address: 100


TIER 3	TIER 2	TIER 1	TIER 0
<b>3,</b>	<b>22</b>	<b>0,1</b>	<b>00</b>

# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Stat Setup Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Stat Setup Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION


### Diagnostic Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Diagnostic Menu.



### Polling Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Polling Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Time/Date Set Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Time/Date Set Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Schedule Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Schedule Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Operation Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Operation Menu.




# PRICE ROOFTOP UNIT CONTROLLER

## DISPLAY NAVIGATION

### Wizard Menu

Once in Service Menu, Scroll Down and Press 'Menu/Enter' to enter the Wizard Menu.



**NOTE:** The Wizard will force you to go through all settings in order. You can re-run the wizard at any time by going through the Service Menu.

# PRICE ROOFTOP UNIT CONTROLLER

## MAINTENANCE

### Troubleshooting Guide

Fault	Symptom	Solution
<b>Doesn't power on</b>	All lights are off (including 24VAC LED)	Check & replace the fuse with a standard 10 Amp automotive style fuse. Check for 24VAC +-10%.
<b>BACnet doesn't communicate</b>	BACnet TX light is blinking green, RX is off	Ensure all BACnet cables are connected between everything on the local BACnet network.
	BACnet does not share a common reference	Ensure all units that are connected via the local BACnet network share a common ground (Earth) connection and that (+) and (-) are connected correctly.
	BACnet HLH LED is red	The PRTU is detecting traffic, but it is all corrupted. Check that the network length is below 1050 feet. All baud rates are the same, each device has a unique MAC and INSTANCE. <b>NOTE:</b> No more than 30 MS/TP devices per segment.
	BACnet HLH LED is solid yellow	The PRTU is detecting traffic, but it is partially corrupted. Check that the network length is below 1050 feet. All baud rates are the same, each device has a unique MAC and INSTANCE.
	BACnet HLH LED is blinking yellow	Ensure all BACnet cables are connected between everything on the local BACnet network. This says the PRTU detects no devices whatsoever.
<b>Binary Output isn't working</b>	Power selector switch is set incorrectly	The power selector switch needs to be fully down to switch 24VAC, fully up to switch ground and in the middle to switch external power.
	Corresponding LED is red	The output is shorted, this will have to be resolved for normal operation.
	Corresponding LED is blinking yellow	There is a BACnet override in place, that is forcing it off, this will have to be removed for the unit to control the output.
	Corresponding LED is solid yellow	There is a BACnet override in place, that is forcing it on, this will have to be removed for the unit to control the output.

# PRICE ROOFTOP UNIT CONTROLLER

## MAINTENANCE

### Troubleshooting Guide

Fault	Symptom	Solution
<b>Analog Input isn't working</b>	Corresponding LED is solid yellow	There is BACnet override in place, this will have to be removed for the input to respond as expected.
	Corresponding LED is red	(0-10 Input) The voltage to the input is exceeding 10VDC. In addition, if the voltage is sufficiently high, it will cause corruption to the other analog inputs.  (Temperature Input) The temperature being read is over 250°F (120°C), check the attached temperature probe. Price temperature probes should read 10,000 (10k) ohms at 77°F (25°C).
<b>Analog Output isn't working</b>	Corresponding LED is solid yellow	There is a BACnet override in place, this will have to be removed for the output to respond as expected.
	Corresponding LED is blinking yellow	There is a BACnet override in place forcing the output off, this will have to be removed for the output to respond as expected.
	Corresponding LED is red	There is a short on the output, it will have to be fixed before the output will work as expected.
<b>T-Stat isn't working</b>	T-Stat is not turning on	Check that the cable is plugged into both the T-Stat and the PRTU.
	STA LED next to T-Stat port is yellow	The PRTU is unable to detect the T-Stat, check the cable.
	STA LED next to T-Stat port is blinking yellow	The temperature probe in the T-Stat is shorted, check the cable and the T-Stat.
	STA LED next to T-Stat port is red	The temperature sensor in the T-Stat is shorted out.

# PRICE ROOFTOP UNIT CONTROLLER

## MAINTENANCE

### Hardware Specifications

<b>Power Requirements</b>	24VAC, 47-63 Hz 10VA (not including output loading) NEC Class II Use only Limited Power Source LPS rated 100VA Max
<b>Ambient Ratings</b>	10°C to 50°C (50°F to 122°F) 0% to 95% RH (non-condensing)
<b>Outputs</b>	<p>[10] 24VAC Binary Outputs. Configurable. Max 0.5 Amps each External power must be 24 VAC Max</p> <ul style="list-style-type: none"> <li>• Fan</li> <li>• Heat 1, Heat 2, Heat 3, Heat 4</li> <li>• Cool 1, Cool 2, Cool 3, Cool 4</li> <li>• Heat Enable</li> <li>• Cool Enable</li> </ul> <p>[4] Analog 0-10VDC. Configurable. Max: 10mA each</p> <ul style="list-style-type: none"> <li>• Fan (ECM)</li> <li>• Heat</li> <li>• Cool</li> <li>• Aux</li> </ul>
<b>Inputs</b>	<p>[6] Analog 0-10V inputs, 67.5k ohm input impedance [6] Thermistor Sensor, Type J 10k ohm Thermistor [2] Binary Inputs (Dry Contact Closure) [1] Thermostat Input, Type J 10k ohm Temperature Sensor (RJ45 Connection)</p> <ul style="list-style-type: none"> <li>• Accuracy of +/- 0.5°F from 55°F to 85°F (+/- 0.25°C from 13°C to 25°C)</li> </ul> <p>3-Way Switch For Binary Outputs</p> <ul style="list-style-type: none"> <li>• Down: Internal 24VAC (Default)</li> <li>• Up: COM</li> <li>• Middle: External Power eat Enable</li> <li>• Cool Enable</li> </ul> <p>10A Fuse Mini (Note: Replace with 10A Mini-Blade Auto Fuse)</p>
<b>Communication ports</b>	<p>BACnet MS/TP Connection with RJ45 Jack and 3-Position Terminal Block</p> <ul style="list-style-type: none"> <li>• Communication speeds: 9,600, 19,200, 38,400, 76,800 (default)</li> <li>• Maximum recommended devices per MS/TP segment: 30 devices</li> <li>• For local setup using Price USB LINKER service tool</li> </ul>
<b>Size</b>	8.25" x 3.55" x 2.25"
<b>Weight</b>	0.8lb. (400g)

# PRICE ROOFTOP UNIT CONTROLLER

## COMMISSIONING CHECKLIST

### Price Controls Commissioning Checklist

The following items shall be verified by the commissioning technician on site. Ideally, the mechanical contractor or controls contractor should be present when the commissioning technician is on site verifying Price equipment.

#### Initial Check:

- All controls parts supplied by Price must be inspected for damage due to shipping, and for proper installation. This includes PRTU rooftop controller, PIC controllers, Prodigy diffusers, thermostat cables and BACnet network
- All applicable Service and Installation (S&I) Manuals are present. If not please download from: **[www.priceindustries.com/controls](http://www.priceindustries.com/controls)**
- All zone Rooftop units must be installed and operational.
  - RTU fan is operational
  - RTU cooling stages are operational
  - RTU heating stages are operational

#### PRTU (Rooftop Controller) check and startup:

Wiring (From RTU to PRTU controller)

- Ensure wiring is complete between RTU and PRTU controller
- PRTU must be powered from the rooftop unit with 24 VAC. Proper hot and common polarity must be observed.
- 24 VAC HOT from RTU wired to PRTU – 24 VAC terminal
- 24 VAC COM from RTU wired to PRTU – COM terminal. Also, this must be earth grounded.
- Fan, cooling stages, and heating stages are properly wired to binary outputs on PRTU.
- PRTU switch output type s selected to proper output type. Default: Down is 24 VAC switched HOT outputs.
- Discharge Air Temperature (DAT) probe installed in RTU discharge ductwork. Correctly wired to AI1.
- Return Air Temperature (RAT) probe installed in RTU return ductwork. Correctly wired to AI2.
- PRTU thermostat installed in a convenient place for the user that also can measure the room temperature of the general zone being controlled.
- PRTU thermostat wired properly with included plug-and-play NETC35 cable.

#### Setup Wizard:

- Complete the Setup Wizard on PRTU. Set the appropriate # of stages, mode, time, schedule, etc.
- Verify fan comes on within 10 seconds of powering up PRTU controller after setup wizard has run. Ensure BO1 output LED is green. Note: Red indicates overload and/or short circuit.
- Check duct probe readings on T-stat. Go into Service Menu -> INPUT and confirm proper DAT and RAT temperature readings. Note: -59 °F indicates no sensor is connected.

# PRICE ROOFTOP UNIT CONTROLLER

## COMMISSIONING CHECKLIST

### Price Controls Commissioning Checklist Continued

The following items shall be verified by the commissioning technician on site. Ideally, the mechanical contractor or controls contractor should be present when the commissioning technician is on site verifying Price equipment.

#### PIC/Prodigy (Zone Controller) check and startup:

- Duct work and VAV boxes / Prodigy units are installed correctly.
- VAV controllers (PIC) / Prodigy diffusers have 24 VAC power via transformer or Price Power Module (PPM) and HOT/COM polarity is observed.
- 24 VAC COM must be earth grounded.
- In cases where a PPM is used, line voltage must be supplied to the PPM unit, and the 24 VAC cables from this unit must be run to the VAV / Prodigy controllers and plugged in. These are C35 cables, usually white or grey.

#### BACnet Network:

- Network is run in a daisy chain format (not bus or star configuration).
- BACnet cables (NETC35) are plugged into BACnet jacks on BACnet expansion boards.
- If Price NETC35 BACnet cables are not being used, 3-position terminal block from the network must be wired and polarity is maintained throughout. (See appropriate Installation Manual for detail).
- RX and TX (receive and transmit) lights are flashing consistently on the BACnet expansion board and yellow BACnet fault LED is not lit.
- MAC address dip switches are set to the correct MAC address – i.e. 1, 2, 3 etc.
- Device instance addresses are set (this is done through the LCD stat or Linker device supplied for the job).
- Thermostats for the PIC / Prodigy units are mounted on the wall and in the appropriate area to control the VAV box or diffuser. Thermostat cable is connected properly at both ends.

#### PCV (bypass box) check and startup:

- PCV round duct damper is installed in proper part of the duct work and will operate as a bypass damper.
- Duct static probe is installed 2/3 of the way downstream of the PCV unit.
- Duct static probe is pneumatically piped back to the HI side (red) of the transducer on the PCV controller. Low side (green) of the transducer is left open.
- PCV cross-flow sensor (SP300) should be completely disconnected. No tubing from this sensor should be connected to the controller.









---

This document contains the most current product information as of this printing.  
For the most up-to-date product information, please go to [priceindustries.com](http://priceindustries.com)

© 2025 Price Industries Limited. All rights reserved.

**PRICE**<sup>®</sup>